



# Purchasing Department

161 West Michigan Avenue – Jackson, Michigan 49201  
Telephone: (517) 788-4020 – Facsimile: (517) 788-4630

July 2, 2009

## ADDENDUM NO.1

### HOUSING REHABILITATION AT 234 E. HIGH ST.

#### Prospective Bidders:

Notice is hereby given that the following additional information and changes shall become part of the specifications of the above referenced contract. You are to certify that you have received and understood the contents by signing one (1) copy of Addendum No. 1 and submitting it with your bid on THURSDAY, JULY 9, 2009, 1:30 PM.

1. Item No. 22: Omit
2. Item No. 43: Should read as follows:

#### STAIRS - CELLAR

**\*\*PERMIT REQUIRED\*\***

Remove existing cellar stairs. Construct new cellar stairs. Stairs to be wooden, closed riser construction, having 2" x 12" fir stringers, resting on concrete floor, 2" x 10" treads, and complete with round pine handrail. All work to conform to code and G.S. 2.

Location: CELLAR STAIRS (**LANDING AND LOWER SECTION ONLY**)

(WET SCRAPE/REPAIR/STABILIZE AND PAINT, UPPER STRINGERS)

(WET SCRAPE/REPAIR/STABILIZE AND PAINT WEST WALL. CURRENTLY (GREY) IN STAIRWAY

3. Item No. 47: Add

Lead Clearance Testing    \$ \_\_\_\_\_

CLARIFICATION: Please note that there is no number 23 in specifications.

Date: \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Company: \_\_\_\_\_

Address: \_\_\_\_\_

City, State, Zip, Phone: \_\_\_\_\_

**NOTE: This form must be included when you submit your bid.**