



Purchasing Department

161 West Michigan Avenue – Jackson, Michigan 49201
Telephone: (517) 788-4020 – Facsimile: (517) 788-4630

July 2, 2009

ADDENDUM NO.1

HOUSING REHABILITATION AT 813 SEYMOUR

Prospective Bidders:

Notice is hereby given that the following additional information and changes shall become part of the specifications of the above referenced contract. You are to certify that you have received and understood the contents by signing one (1) copy of Addendum No. 1 and submitting it with your bid on THURSDAY, JULY 9, 2009, 1:30 PM.

1. Item No. 6: OMIT.
2. Item No. 26: Should read as follows:

PLASTER - PATCHING PLASTER - PATCHING

Remove all loose and deteriorated plaster around broken areas. Cut all cracks in an inverted "V." Tighten lath as required. Moisten opening and patch plaster using prepared patching plaster mix. Preparation, application, and curing shall strictly follow the manufacturer's printed directions.

Location: HALL WALLS & BED ROOM N.W. **WALLS AND CEILING.**

3. Item No. 33: Basement. Add Item No. 6. Furnish new cap at clean out for main stack.
4. Item No. 34: Omit Basement Item No. 3.

Date: _____
By: _____
Title: _____
Company: _____
Address: _____
City, State, Zip, Phone: _____

NOTE: This form must be included when you submit your bid.